

From: [Higgins, Thomas](#)
To: [Vachon, Adam](#)
Cc: [Collette, Anja](#)
Subject: RE: Lancaster Ave, The Maine Woods Subdivision
Date: Wednesday, November 15, 2023 10:05:01 AM
Attachments: [image001.png](#)

Adam,

Thank you for reviewing the plans for Maine Wood sub-division on Lancaster Avenue. I approve/accept your review as presented.

Chief Higgins



CITY OF BANGOR

Thomas E. Higgins CEM-ME, MECFO II
Fire Chief / Emergency Management Director

Fire Department

Phone: 207-992-4701

Cell: 207-852-5142

Fax: 207-942-8213

From: Vachon, Adam <adam.vachon@bangormaine.gov>
Sent: Thursday, 9 November 2023 10:54 AM
To: Higgins, Thomas <thomas.higgins@bangormaine.gov>
Subject: Lancaster Ave, The Maine Woods Subdivision

Good morning Chief, on your behalf inspector Craig and I have independently reviewed plans for the proposed fire hydrant locations in The Maine Woods Subdivision off of Lancaster Ave. This plan shows the addition of 2 hydrants, located near both intersections of Wildwood Drive and Firefly Lane. These Hydrants and their locations meet the water supply requirements for this subdivision, as called out in NFPA 1 2018 edition, chapter 18.3. It is my recommendation that the hydrant locations be approved as submitted.

Respectfully Submitted,
Adam Vachon



CITY OF BANGOR

Adam Vachon

Fire Inspector, CFI-1

Fire Prevention Division

Phone: 207-992-4180

Cell: 207-735-6468

Fax: 207-945-4449

<http://www.bangormaine.gov>